



Ernie Fletcher  
Governor

Teresa J. Hill, Secretary  
Environmental and Public  
Protection Cabinet

Timothy J. LeDonne  
Commissioner  
Department of Public Protection

Roger Moss  
General Manager  
Green-Taylor Water District  
250 Industrial Park Road  
P. O. Box 168  
Greensburg, KY 42743

Commonwealth of Kentucky  
**Public Service Commission**  
211 Sower Blvd.  
P.O. Box 615  
Frankfort, Kentucky 40602-0615  
Telephone: (502) 564-3940  
Fax: (502) 564-3460  
psc.ky.gov

Mark David Goss  
Chairman

John W. Clay  
Commissioner

August 13, 2007

CERTIFICATE OF SERVICE

RE: Case No. 2007-00271  
Green-Taylor Water District

I, Beth O'Donnell, Executive Director of the Public Service Commission, hereby certify that the enclosed attested copy of the Commission's Order in the above case was served upon the addressee by U.S. Mail on August 13, 2007.

A handwritten signature in black ink, appearing to read "Beth O'Donnell", written over a horizontal line.

Executive Director

BOD/tw  
Enclosure

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GREEN-TAYLOR WATER	)	
DISTRICT FOR A DEVIATION FROM THE	)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION	)	2007-00271
4(4), REGARDING WATER STORAGE	)	

O R D E R

On July 2, 2007, the Green-Taylor Water District ("Green-Taylor") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Green-Taylor states in its application that its average daily water usage, including unaccounted-for water, is approximately 975,000 gallons, and that its current water storage capacity is 860,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Green-Taylor is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Green-Taylor states in its application that funds are already in place from a state grant to replace its existing 60,000-gallon Black Gnat Water Storage Tank with a 500,000-gallon elevated water storage tank.
3. Because of the time needed to plan, finance, and construct water storage facilities, Green-Taylor should have until January 1, 2009 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Green-Taylor shall have until January 1, 2009 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Green-Taylor shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2009.

Done at Frankfort, Kentucky, this 13<sup>th</sup> day of August, 2007.

By the Commission

ATTEST:



Executive Director